



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78758 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

**LEAD/COPPER
Analysis Report**

Submitter Identification Number: 1050019

GOFORTH SUD
SANDOVAL, DEBBIE
8900 NIEDERWALD STRASSE
NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
Report ID# : 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD47770 Sample #: DS01 LCR001 Year: 2016 Period :
Collection Date: 08/31/2016 Collection Address: 1088 HOLZ RD ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0011	mg/L	09/14/2016	IU
Copper	0.436	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47771 Sample #: DS01 LCR002 Year: 2016 Period :
Collection Date: 09/02/2016 Collection Address: 989 HOLZ RD ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0098	mg/L	09/14/2016	IU
Copper	0.599	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47772 Sample #: DS01 LCR003 Year: 2016 Period :
Collection Date: 09/02/2016 Collection Address: 1513 HOLZ RD ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0018	mg/L	09/14/2016	IU
Copper	0.111	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47773 Sample #: DS01 LCR004 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 371 SCHUELKE RD ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0022	mg/L	09/14/2016	IU
Copper	0.219	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.

1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**LEAD/COPPER
Analysis Report**

Submitter Identification Number: 1050019

GOFORTH SUD
SANDOVAL, DEBBIE
8900 NIEDERWALD STRASSE
NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
Report ID#: 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD47774 Sample #: DS01 LCR005 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 8900 NIEDERWALD STRASSE ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.587	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47775 Sample #: DS01 LCR006 Year: 2016 Period :
Collection Date: 09/02/2016 Collection Address: 12935 ELM GROVE RD ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.483	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47776 Sample #: DS01 LCR007 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 15288 CAMINO REAL ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.308	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47777 Sample #: DS01 LCR008 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 15260 CAMINO REAL ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.335	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

**LEAD/COPPER
Analysis Report**

Submitter Identification Number: 1050019

GOFORTH SUD
SANDOVAL, DEBBIE
8900 NIEDERWALD STRASSE
NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
Report ID# : 20160920110756AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD47778 Sample #: DS01 LCR009 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 15200 CAMINO REAL ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.297	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47779 Sample #: DS01 LCR010 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 15210 CAMINO REAL ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.307	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47780 Sample #: DS01 LCR012 Year: 2016 Period :
Collection Date: 08/31/2016 Collection Address: 900 SCHUBERT RD ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0013	mg/L	09/14/2016	IU
Copper	0.144	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47782 Sample #: DS01 LCR015 Year: 2016 Period :
Collection Date: 09/01/2016 Collection Address: 202 PEGGYS TRAIL ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0242	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.

Submitter Identification Number: 1050019

GOFORTH SUD
 SANDOVAL, DEBBIE
 8900 NIEDERWALD STRASSE
 NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
 Report ID# : 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD48281 Sample #: DS01 LCR011 Year : 2016 Period :
 Collection Date: 09/08/2016 Collection Address: 14712 CAMINO REAL ✓
 Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0132	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48282 Sample #: DS01 LCR013 Year : 2016 Period :
 Collection Date: 09/07/2016 Collection Address: 206 WINDRIDGE DR ✓
 Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0020	mg/L	09/14/2016	IU
Copper	0.0963	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48283 Sample #: DS01 LCR016 Year : 2016 Period :
 Collection Date: 09/07/2016 Collection Address: 839 PETRAS WAY ✓
 Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0481	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48284 Sample #: DS01 LCR017 Year : 2016 Period :
 Collection Date: 09/07/2016 Collection Address: 600 ENGELKE RD ✓
 Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0012	mg/L	09/14/2016	IU
Copper	0.0504	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.



Texas Department of State Health Services

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**LEAD/COPPER
 Analysis Report**

Submitter Identification Number: 1050019

GOFORTH SUD
 SANDOVAL, DEBBIE
 8900 NIEDERWALD STRASSE
 NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
 Report ID# : 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD47783 Sample #: DS01 LCR018 Year: 2016 Period :
 Collection Date: 09/01/2016 Collection Address: 1800 ROHDE RD ✓
 Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.287	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47784 Sample #: DS01 LCR019 Year: 2016 Period :
 Collection Date: 09/01/2016 Collection Address: 401 LOVE DR ✓
 Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0120	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47785 Sample #: DS01 LCR021 Year: 2016 Period :
 Collection Date: 09/01/2016 Collection Address: 14009 CAMINO REAL ✓
 Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.183	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47786 Sample #: DS01 LCR022 Year: 2016 Period :
 Collection Date: 08/31/2016 Collection Address: 8301 NIEDERWALD ST ✓
 Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.150	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-063-7111
www.dshs.state.tx.us

**LEAD/COPPER
Analysis Report**

Submitter Identification Number: 1050019

GOFORTH SUD
SANDOVAL, DEBBIE
8900 NIEDERWALD STRASSE
NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
Report ID# : 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD47787 Sample # : DS01 LCR024 Year : 2016 Period :
Collection Date: 09/01/2016 Collection Address: 106 OLD WEST ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0218	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47788 Sample # : DS01 LCR025 Year : 2016 Period :
Collection Date: 09/02/2016 Collection Address: 205 LOVE DR ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0186	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47789 Sample # : DS01 LCR026 Year : 2016 Period :
Collection Date: 09/01/2016 Collection Address: 4111 DACY LN ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0140	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD47790 Sample # : DS01 LCR027 Year : 2016 Period :
Collection Date: 09/01/2016 Collection Address: 7707 NIEDERWALD DR ✓
Date Received: 09/02/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0053	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.

1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

**LEAD/COPPER
Analysis Report**

Submitter Identification Number: 1050019

GOFORTH.SUD
SANDOVAL, DEBBIE
8900 NIEDERWALD STRASSE
NIEDERWALD, TX 78640-4034

Date Reported : 09/20/2016
Report ID#: 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD48285 Sample #: DS01 LCR020 Year : 2016 Period :
Collection Date: 09/07/2016 Collection Address: 103 DUNNY RIDGE DR ✓
Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.106	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48286 Sample #: DS01 LCR023 Year : 2016 Period :
Collection Date: 09/08/2016 Collection Address: 8004 NIEDERWALD ST ✓
Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0287	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48287 Sample #: DS01 LCR029 Year : 2016 Period :
Collection Date: 09/07/2016 Collection Address: 418 HIGH RD ✓
Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0011	mg/L	09/14/2016	IU
Copper	0.262	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48288 Sample #: DS01 LCR035 Year : 2016 Period :
Collection Date: 09/08/2016 Collection Address: 7703 NIEDERWALD STRASSE ✓
Date Received: 09/08/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0010	mg/L	09/14/2016	IU
Copper	0.0142	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
AUSTIN, TEXAS 78714-9347
1-888-963-7111
www.dshs.state.tx.us

**LEAD/COPPER
Analysis Report**

Submitter Identification Number: 1050019

GOFORTH SUD
SANDOVAL, DEBBIE
8900 NIEDERWÄLD STRASSE
NIEDERWÄLD, TX 78640-4034

Date Reported : 09/20/2016
Report ID# : 20160920110758AD47770

Method : EPA 200.8 Action Levels: Lead(Pb) = 0.015 mg/L Copper(Cu) = 1.30 mg/L

Lab Number: AD48685 Sample #: LCR031 Year : 2016 Period :
Collection Date: 09/12/2016 Collection Address: 204 SUSAN DR ✓
Date Received: 09/12/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	< 0.0010	mg/L	09/14/2016	IU
Copper	0.0207	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48686 Sample #: LCR032 Year : 2016 Period :
Collection Date: 09/12/2016 Collection Address: 136 SHASTA COVE ✓
Date Received: 09/12/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0012	mg/L	09/14/2016	IU
Copper	0.0733	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Lab Number: AD48687 Sample #: LCR033 Year : 2016 Period :
Collection Date: 09/09/2016 Collection Address: 2545 SCHUELKE RD
Date Received: 09/12/2016

Analyte	Results	Units	Date Analyzed	Analyst
Lead	0.0016	mg/L	09/14/2016	IU
Copper	0.0305	mg/L	09/14/2016	IU

Authorized by Team Lead EBOYER on 09/16/2016

Unless otherwise noted, the results on this report relate only to the sample(s) identified on this report and meets all NELAC requirements.

Goforth SUD
8900 Niederwald Strasse
Kyle, Texas 78640
Lead Copper Analytical Results

SAMPLE ID	SAMPLE ADDRESS	SAMPLE DATE	Lead (Pb) (mg/L)	Copper (Cu) (mg/L)
Federal Action Level			0.015	1.30
LCR001	1088 Holz Rd	8/31/2016	0.0011	0.436
LCR002	989 Holz Rd	9/2/2016	0.0098	0.599
LCR003	1513 Holz Rd	9/2/2016	0.0018	0.111
LCR004	371 Schuelke Rd	9/1/2016	0.0022	0.219
LCR005	8900 Niederwald Strasse	9/1/2016	< 0.0010	0.587
LCR006	12935 Elm Grove Rd	9/2/2016	< 0.0010	0.483
LCR007	15288 Camino Real	9/1/2016	< 0.0010	0.308
LCR008	15260 Camino Real	9/1/2016	< 0.0010	0.335
LCR009	15200 Camino Real	9/1/2016	< 0.0010	0.297
LCR010	15210 Camino Real	9/1/2016	< 0.0010	0.307
LCR011	14712 Camino Real	9/6/2016	< 0.0010	0.0132
LCR012	900 Schubert Rd	8/31/2016	0.0013	0.144
LCR013	206 Windridge Dr	9/7/2016	0.0020	0.0963
LCR015	202 Peggys Trail	9/1/2016	< 0.0010	0.0242
LCR016	839 Petras Way	9/7/2016	< 0.0010	0.0481
LCR017	600 Engelke Rd	9/7/2016	0.0012	0.0504
LCR018	1800 Rohde Rd	9/1/2016	< 0.0010	0.287
LCR019	401 Love Rd	9/1/2016	< 0.0010	0.0120
LCR020	103 Dunny Ridge Dr	9/7/2016	< 0.0010	0.106
LCR021	14009 Camino Real	9/1/2016	< 0.0010	0.183
LCR022	8301 Niederwald St	8/31/2016	< 0.0010	0.150
LCR023	8004 Niederwald St	9/8/2016	< 0.0010	0.0287
LCR024	106 Old West	9/1/2016	< 0.0010	0.0218
LCR025	205 Love Dr	9/2/2016	< 0.0010	0.0186

Goforth SUD
8900 Niederwald Strasse
Kyle, Texas 78640
Lead Copper Analytical Results

LCR026	4111 Dacy Ln	9/1/2016	< 0.0010	0.0140
LCR027	7707 Niederwald Dr	9/1/2016	< 0.0010	0.0053
LCR029	418 High Rd	9/7/2016	0.0011	0.262
LCR031	204 Susan Dr	9/12/2016	< 0.0010	0.0207
LCR032	136 Shasta Cove	9/12/2016	0.0012	0.0733
LCR033	2545 Schuelke Rd	9/9/2016	0.0016	0.0305
LCR035	7703 Niederwald Strasse	9/8/2016	0.0010	0.0142